



Government Of West Bengal
Office Of The Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Bardhaman, P.O.:- Rajbati, Pin :- 713104

Memo no.: FSR/0125186210300055

Date: 28-10-2021

From:

Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services

To: Katwa College (B.Ed.)

Holding No. 07, Ward No. 03, Village and P.O.- Katwa, Mouza- Katwa , Over Plot No. 574 to 576, 579, 43, 580, 35, 79, Khatian No. 2925, 2918, 2916/1, 80, 12, J.L. No. 21, 23, P.S. Katwa, Dist.- Purba

Sub: Sir, it is a case of F/S/C of a G+2 storied Educational Building named Katwa College (B.Ed.) at over Holding no. 07, Ward no. 03, Vlii, P.O Katwa, mouza Katwa, Plot no. 574 to 576, 579, 43 , 580, 35, 79, Kh. no. 2925, 2918, 2916/1, 80, 12, J.L no. 21, 23, P.S Katwa, Dist. Purba Bardhaman, Pin 713130.

This is in reference to your application no. 0125189210300090 dated 26-10-2021 regarding the Sir, it is a case of F/S/C of a G+2 storied Educational Building named Katwa College (B.Ed.) at over Holding no. 07, Ward no. 03, Vlii, P.O Katwa, mouza Katwa, Plot no. 574 to 576, 579, 43 , 580, 35, 79, Kh. no. 2925, 2918, 2916/1, 80, 12, J.L no. 21, 23, P.S Katwa, Dist. Purba Bardhaman, Pin 713130.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

Recommmandation

1. Driveway must be free of any obstruction for easy movement of Fire Appliances. No Parking will be allowed in the Drive Way.
2. The Interior finish decoration of building shall be made with low flame spread material conforming to the I.S. Specification.
3. To eliminate of fire hazard, Good Housekeeping both inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the entire building shall have to be carefully checked for any wear and tear in them, particularly line above false ceiling & ducts.
5. The Exit Sign and fire notice shall be maintained from fading and dust sedimentation and prepared and displayed at all venerable place.
6. The employees and Security staffs shall be conversant with installed Fire Fighting Equipments of the building and operate in the event of fire and testing.

7. Mock Fire Practice and Evacuation Drill shall be performed periodically with participation of all the occupant of the building.
8. Special training to employees and staffs shall be give for carrying the ambulant(s) to the safe replace in the event of any exigency.
9. Meter and Main room shall be removed to outside of the building and be protected with CO2 or D.C.P. Modular Fire Extinguishers.
10. A Crew of trained fireman under an experienced officer shall be maintained round the clock for safety of the building and its occupants
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good condition at all the time.
12. Install the down comer from O/H tank(main dia 150mm).
13. First Aid Fire Fighting Equipment shall be made to maintain the efficiency working performance of the Fire Fighting System Installed.
14. The Fire Safety Audit to be conducted at a regular interval and to be recorded in the Fire Prevention Maintenance Register.
15. The Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Signature valid

Digitally signed by PULACK
SHARMA
Date: 2021.10.29 16:12:10 IST

Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services